

FINAL REPORT

CERTIFICATE No.: 27688



Boral Cement Limited

ABN 62 008 528 523

Taylor Avenue New Berrima NSW 2577

Locked Bag 4 New Berrima NSW 2577

T +61 2 4860 2222

TEST CERTIFICATE OF: Geelong Daily Despatch General Purpose Bulk Cement
PRODUCED AT: Boral Cement Limited Geelong
TESTED AT: Boral Cement QA Laboratory
SAMPLE IDENTIFICATION: GDDGP2504284
DATE DESPATCHED: 3/11/2025

| PROPERTY | REQUIREMENTS OF AS 3972 | | | RESULT |
|-----------------------------------|-------------------------|----------|--|----------|
| Compressive Strength (AS 2350.11) | | | | |
| 3 Day | | | | 38.7 MPa |
| 7 Day | Minimum | 35 MPa | | 48.9 MPa |
| 28 Day | Minimum | 45 MPa | | 61.5 MPa |
| Setting Time (AS 2350.4) | | | | |
| Initial | Minimum | 45 mins | | 120 mins |
| Final | Maximum | 360 mins | | 150 mins |
| Soundness (AS 2350.5) | Maximum | 5 mm | | 1 mm |
| SO ₃ (AS 2350.2) | Maximum | 3.5 % | | 3.0 % |
| CI (AS 2350.2) | Maximum | 0.10 % | | 0.02 % |

OTHER REPORTABLE PROPERTIES

CHEMICAL

| | |
|-------------------------------|--------|
| K ₂ O (AS 2350.2) | 0.39 % |
| Na ₂ O (AS 2350.2) | 0.28 % |
| LOI (AS 2350.2) | 2.6 % |

PHYSICAL

| | |
|--------------------------------|------------------------|
| Normal Consistency (AS 2350.3) | 27.8 % |
| Fineness Index (AS 2350.8) | 375 m ² /kg |

REMARKS

Preparation of mortar and moulding of specimens in accordance with AS 2350.12.

Sampling not carried out by laboratory. Samples tested as received and results only relate to the item tested.

This cement is a Type GP cement with up to 7.5% mineral addition.

Melody Mancenido
(Technical Services Manager)

Date of Issue: 1/15/2026



Accredited for compliance with ISO/IEC 17025 - Testing

NATA Accreditation Number: 530

Page 1 of 1