FINAL REPORT

CERTIFICATE No.: 28609

Boral Cement Limited
ABN 62 008 528 523
Taylor Avenue New Berrima NSW 2577
Locked Bag 4 New Berrima NSW 2577
T +61 2 4860 2222

TEST CERTIFICATE OF: Geelong Daily Despatch General Purpose Bulk Cement
PRODUCED AT: Boral Cement Limited Geelong
TESTED AT: Boral Cement QA Laboratory
SAMPLE IDENTIFICATION: GDDGP2603405
DATE DESPATCHED: 16/08/2026

PROPERTY	REQUIREMENTS OF AS 3972			RESULT
Compressive Strength (AS 2350.11)				
3 Day				34.6 MPa
7 Day	Minimum	35	MPa	44.9 MPa
28 Day	Minimum	45	MPa	56.9 MPa
Setting Time (AS 2350.4)				
Initial	Minimum	45	mins	120 mins
Final	Maximum	360	mins	135 mins
Soundness (AS 2350.5)	Maximum	5	mm	0 mm
SO_3 (AS 2350.2)*	Maximum	3.5	%	2.9 %
Cl (AS 2350.2)*	Maximum	0.10	%	0.01 %

OTHER REPORTABLE PROPERTIES

CHEMICAL			PHYSICAL		
K_2O	(AS 2350.2)*	0.43 %	Normal Consistency	(AS 2350.3)	27.7 %
Na_2O	(AS 2350.2)*	0.18 %	Fineness Index	(AS 2350.8)	395 m^2/kg
LOI	(AS 2350.2)*	3.8 %			

REMARKS

Preparation of mortar and moulding of specimens in accordance with AS 2350.12.

Sampling not carried out by laboratory. Samples tested as received and results only relate to the item tested.

This cement is a Type GP cement with up to 7.5% mineral addition.

*The authorised signatory for AS2530.2 is Taleb Hallal

Jimmy Zhang
Senior Laboratory Technician

Taleb Hallal
Chemical Analyst

Accredited for compliance with ISO/IEC 17025 - Testing

NATA Accreditation Number: 530

Date of Issue: 15/10/2026