



**SOURCE EMISSIONS MONITORING – KYOGLE TIMBER PLANT**

**BORAL TIMBER**

Project ID. 11141

**R\_0**

**DATE OF RELEASE: 29/11/2017**

Table 1: Document approval




	Name	Position Title	Signature	Date
Author	Zac Heironymus	Technician		23/11/2017
Reviewer	Glenn Ward	Principal Scientist		29/11/2017
Approved	Glenn Ward	Principal Scientist		29/11/2017

Table 2: Revision register

Revision	Date	Issuer	Recipient	Comment
R_0	29/11/2017	G. Ward	R. Cox	Initial Release

## DISCLAIMER

Assured Monitoring Group acts in all professional matters as a faithful advisor to the Client and exercises all reasonable skill and care in the provision of its professional services.

Reports are commissioned by and prepared for the exclusive use of the Client. They are subject to and issued in accordance with the agreement between the Client and Assured Monitoring Group. Assured Monitoring Group is not responsible for any liability and accepts no responsibility whatsoever arising from the misapplication or misinterpretation by third parties of the contents of its reports.

Except where expressly stated, Assured Monitoring Group does not attempt to verify the accuracy, validity or comprehensiveness of any information supplied to Assured Monitoring Group for its reports.

Reports cannot be copied or reproduced in whole or part for any purpose without the prior written agreement of Assured Monitoring Group.

Where site inspections, testing or fieldwork have taken place, the report is based on the information made available by the client or their nominees during the visit, visual observations and any subsequent discussions with regulatory authorities. The validity and comprehensiveness of supplied information has not been independently verified and, for the purposes of this report, it is assumed that the information provided to Assured Monitoring Group is both complete and accurate. It is further assumed that normal activities were being undertaken at the site on the day of the site visit(s), unless explicitly stated otherwise.

## ACCREDITED FOR COMPLIANCE TO ISO/IEC 17025

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Accreditation ID: 19703



## EXECUTIVE SUMMARY

The following table provides a summary of results from emission monitoring on the main stack (EPA Point 1) at the Boral Timber facility located near Kyogle, NSW. The emission sampling completed on the main stack release point was undertaken in order to determine the concentration and emission rate of the parameters listed in Table 3 to satisfy the requirements of NSW EPA Permit number 906.

**Table 3: Summary of results**

Release Point Parameter	Result	Permit Limit	Unit of Measure	Reference Conditions
Process conditions	2.6 Mw (normal)			
Run Start Date	26/10/2017		dd-mm-yy	
Run Start Time	12:00:00 PM		hh:mm	
Run Stop Time	1:20:00 PM		hh:mm	
Carbon Dioxide Percentage	4.85	-	vol-%	
Nitrogen Percentage	77.9	-	%	
Dry Gas Molecular Weight	1.32	-	kg/Nm <sup>3</sup>	
Dry Gas Molecular Weight	29.5	-	g/g-mole	
Wet Stack Gas Molecular Weight	28.9	-	g/g-mole	
Average Stack Gas Velocity	5.80	-	m/sec	
Actual Stack Flow Rate	394	-	m <sup>3</sup> /min	
Dry Standard Stack Flow Rate	244	-	Nm <sup>3</sup> /min-dry	
Stack PM Concentration	2.23	-	mg/Nm <sup>3</sup>	
Stack PM Concentration at 14 % O <sub>2</sub>	4.19	30	mg/Nm <sup>3</sup>	dry, 273 K, 101.3 kPa
Particulate Emission Rate	0.544	-	g/min	
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	59.9	-	mg/Nm <sup>3</sup>	
Nitrogen Oxides at 14 % O <sub>2</sub>	113	-	mg/Nm <sup>3</sup>	dry, 273 K, 101.3 kPa
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	14.6	-	g/min	
Carbon Monoxide (CO)	60.0	-	mg/Nm <sup>3</sup>	
Carbon Monoxide at 14 % O <sub>2</sub>	113	-	mg/Nm <sup>3</sup>	dry, 273 K, 101.3 kPa
Carbon Monoxide (CO)	14.7	-	g/min	

## TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION</b> .....	<b>5</b>
<b>2</b>	<b>METHODOLOGY &amp; EQUIPMENT</b> .....	<b>5</b>
2.1	SAMPLING METHODOLOGY .....	5
2.2	SAMPLING LOCATION .....	6
2.3	PLANT OPERATION .....	7
2.4	TEST EQUIPMENT .....	8
<b>3</b>	<b>QUALITY ASSURANCE &amp; QUALITY CONTROL (QA/QC)</b> .....	<b>9</b>
<b>4</b>	<b>DEFINITIONS</b> .....	<b>10</b>
<b>5</b>	<b>RESULTS</b> .....	<b>11</b>

## LIST OF TABLES

TABLE 1:	DOCUMENT APPROVAL .....	II
TABLE 2:	REVISION REGISTER .....	II
TABLE 3:	SUMMARY OF RESULTS.....	III
TABLE 4:	TEST METHODS.....	5
TABLE 5:	ANALYSIS NOTES .....	5
TABLE 6:	SAMPLING COMMENTS .....	5
TABLE 7:	STACK DESCRIPTION .....	7
TABLE 8:	SAMPLING DATA QA/QC CHECKLIST .....	9
TABLE 9:	LABORATORY DATA QA/QC CHECKLIST.....	9
TABLE 10:	DEFINITIONS.....	10
TABLE 11:	RESULTS SUMMARY .....	11

## LIST OF FIGURES

FIGURE 1:	SITE LOCATION.....	6
FIGURE 2:	SAMPLE PLATFORM LOCATION .....	6
FIGURE 3:	FULL ISOKINETIC SAMPLING ASSEMBLY .....	8
FIGURE 4:	MRU COMBUSTION GAS ANALYSER.....	8

## 1 INTRODUCTION

Assured Monitoring Group (AMG) was appointed by Boral Shared Services to sample and analyse source emissions from their timber facility located in Kyogle, New South Wales. Sampling was conducted by AMG on the 26<sup>th</sup> of October 2017 during typical plant operational activities.

AMG was responsible for the collection and analysis of samples, unless otherwise indicated. The samples were recovered and stored in the appropriate manner until their return to the laboratory where the samples were prepared and analysed according to the methodologies listed below in this report.

## 2 METHODOLOGY & EQUIPMENT

### 2.1 Sampling methodology

All sampling and analysis was carried in accordance to the listed requirements in Table 4. Any deviations to these methods have been documented where required.

**Table 4: Test methods**

Parameter	AS/USEPA Method	NSW Method	Analysis	Comments	NATA
Sample plane criteria	AS 4323.1	TM-1	1	Nil	Yes
Gas velocity and temperature	USEPA M2	TM-2	1	Nil	Yes
Stack gas density	USEPA M3	TM-23	1	Nil	Yes
Oxygen & carbon dioxide	USEPA M3A	TM-23	1	A	Yes
Stack gas water vapour	USEPA M4	TM-22	1	Nil	Yes
Particulate matter	AS 4323.2	TM-15	1	Nil	Yes
Nitrogen oxides	USEPA M7E	TM-11	1	A	Yes
Carbon monoxide	USEPA M10	TM-32	1	A	Yes

**Table 5: Analysis notes**

Note	Company	Work performed	Accreditation	Report Number
1	AMG Pty Ltd	Sampling & analysis	NATA: 19703	11141

**Table 6: Sampling comments**

Note	Comment
A	Pre & post calibration of the analyser was completed in the laboratory.

## 2.2 Sampling location

The below images show the Boral Timber site location and stack location, Kyogle, NSW.




Figure 1: Site location



Figure 2: Sample platform location



**Table 7: Stack description**

Sample location	EPA Point 1
Stack coordinates	UTM
easting	499784.97E
northing	6830484.21S
Stack Exit point from ground (m)	unknown
Stack Shape	CIRCULAR
Stack Diameter (m)	1.2
Stack Cross Section Area (m <sup>2</sup> )	1.13
Distance to upstream disturbance (m)	6.0
Diameters (D)	5.0
Distance to downstream disturbance (m)	8.0
Diameters (D)	6.7
Total traverse point factors	1.05 , 1 , 1.05 , 16
Port size (mm)	100
Port Thread Type	BSP
Number of traverses	2
Number of points per traverse	8
Total number of traverse points	16
Flow & temperature compliance check	YES

### 2.3 Plant operation

During the sampling, the plant was considered to be operating at standard, representative process load. The furnace supplies heat to the drying kilns.

## 2.4 Test equipment

The sampling equipment was transported to site using a company vehicle. The stack sample location is accessible using installed walkways and ladders. All sampling equipment was located on the stack platform and on the ground below, while sample preparation and recoveries were carried in the vehicle which acts as a mobile laboratory. For this project, two complete isokinetic and non-isokinetic sampling trains were used, along with a multi-gas combustion analyser.

All equipment used during the course of the testing is sourced from Apex Instruments, an industry leader in the supply of source testing equipment.



Figure 3: Full isokinetic sampling assembly



Figure 4: MRU combustion gas analyser



### 3 QUALITY ASSURANCE & QUALITY CONTROL (QA/QC)

AMG operates within a quality system based upon the requirements of ISO17025. Our quality system defines specific procedures and methodologies to ensure any project undertaken by AMG is conducted with the highest level of quality given the specific confines of each project

The overall objective of our QA/QC procedures is to representatively sample and accurately analyse components in the gas streams and therefore report valid measurements of emission concentrations.

To ensure representativeness of field work, our quality procedures target:

1. Correct sampling locations
2. Sample time
3. Frequency of samples and
4. Method selection & adherence

To ensure representativeness of lab work, our quality procedures target:

1. Sample preservation
2. Chain of custody (COC)
3. Sample preparation and
4. Analytical techniques

AMG maintains strict quality assurance throughout all its sampling programs, covering on-site 'field work' and the analytical phase of our projects. Our QA program covers the calibration of all sampling and analytical apparatus where applicable and the use of spikes, replicate sample and reference standards. The test methodologies used for this project are outlined in section 2 of this document. Field test data has been recorded and calculated using direct entry into Microsoft Excel spreadsheets following the procedures of the appropriate test methods. Determination of emission concentrations has been performed using the same Microsoft Excel spreadsheets which are partially supplied as an attachment to this report. More detailed information can be supplied upon request.

QA/QC checks for this project will use validation techniques and criteria appropriate to the type of data and the purpose of the measurement to approve the test report. Records of all data will be maintained. Complete chain of custody (COC) procedures has been followed to document the entire custodial history of each sample. The COC forms also served as a laboratory sheet detailing sample ID and analysis requirements.

**Table 8: Sampling data QA/QC checklist**

Sampling Data QA/QC Checklist	Comment
Use of appropriate test methods	Yes
'Normal' operation of the process being tested	Yes – as instructed by Boral
Use of properly operating and calibrated test equipment	Yes
Use of high purity reagents	Yes
Performance of leak checks post sample (at least)	Yes

**Table 9: Laboratory data QA/QC checklist**

Laboratory Data QA/QC Checklist	Comment
Use of appropriate analytical methods	Yes
Use of properly operating and calibrated analytical equipment	Yes
Precision and accuracy comparable to that achieved in similar projects	Yes
Accurate reporting	Yes

## 4 DEFINITIONS

The following terms and abbreviations may be used in this report:

**Table 10: Definitions**

Symbol	Definition
<	The analytes tested for was not detected; the value stated is the reportable limit of detection
Am <sup>3</sup>	Gas volume in cubic metres at measured conditions
AS	Australian Standard
BH	Back half of sample train (filter holder and impingers) (referred to during sample recovery)
°C	Degrees Celsius
CARB	California Air Resources Board methods
dscm	dry standard cubic meters
FH	Front half of sample train (probe and filter holder) (referred to during sample recovery)
f/ml	Fibres per millilitre
g	Grams
kg	Kilograms
m	Metres
m <sup>3</sup>	actual gas volume in cubic metres as measured
mbar	Millibars
mg	Milligrams (10 <sup>-3</sup> grams)
min	Minute
ml	Millilitres
mmH <sub>2</sub> O	Millimetres of water
Mole	SI unit that measures the amount of substance
N/A	Not applicable
ng	Nanograms (10 <sup>-9</sup> grams)
NATO	North Atlantic Treaty Organisation
NIOSH	National institute for occupational safety and health (USA)
Nm <sup>3</sup>	Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa)
NMI	National Measurement Institute
NM VOC	Non methane volatile organic compound
NR	Not required on this occasion
OSHA	Occupational Safety and Health Act
ou	Odour unit
PCDD	Polychlorinated dibenzo- <i>p</i> -dioxin
PCDF	Polychlorinated dibenzofuran
PM	Particulate matter
ppb	Parts per billion
ppm	Parts per million
sec	Second
Sm <sup>3</sup>	Gas volume in dry cubic metres at standard temperature and pressure (0°C and 101.3 kPa) and corrected to a standardised value (e.g. 15% O <sub>2</sub> )
STP	Standard temperature and pressure (0°C and 101.3 kPa)
TO	USEPA air toxics method
TWA	Time weighted average
USEPA	United States Environmental Protection Authority

## 5 RESULTS

Table II: Results Summary

RESULTS				
Source Data			Stack SDS version - 3.1	
Client			Boral Timber	
Site			Kyogle	
Sample Point			EPA Point I	
Reference Method			USEPA Method 5 - ISOKINETIC	
Test Parameters			PM & gases	
Process conditions			2.6 Mw (normal operations)	
Historical Data & Hardware Information - Manual Sample				
Run Start Date		dd-mm-yy	Thursday, 26 October 2017	
Project ID			11141	
Run ID			-1	
Run Start Time	Ti	hh:mm	12:00:00	
Run Stop Time	Tf	hh:mm	13:20:00	
Positioning compliance check with AS4323.1			Non-ideal	
Flow & temperature compliance check with AS4323.1			YES	
Traverse pt factors; up, down, total & trav pts			1.05, 1, 1.05, 16	
Console Serial Number			SN474	
Meter Calibration Factor	(Y)		1.023	
Orifice Coefficient		(DH@)	49.38	
Pitot Tube Coefficient	(Cp)		0.84	
Actual Nozzle Diameter	(Dna)	mm	8.41	
Stack Test Data				
Initial Meter Volume	(Vm)i	m <sup>3</sup>	67.715	
Final Meter Volume	(Vm)f	m <sup>3</sup>	68.750	
Actual Sampling Time	(Q)	minutes	80	
Average Meter Temperature	(tm)avg	°C	33	
Average Stack Temperature	(ts)avg	°C	143	
Barometric Pressure	(Pb)	mb	1009	
Stack Static Pressure	(Pstatic)	mm H <sub>2</sub> O	-10.0	
Absolute Stack Pressure	(Ps)	mb	1008	
Sample Volumes				
Actual Meter Volume	(Vm)	m <sup>3</sup>	1.059	
Standard Meter Volume	(Vm)std	Nm <sup>3</sup>	0.943	
Moisture Content Data				
Water vapour concentration	(Bws(calc))	%	5.10	
Stack Gas Density Analysis Data				
Carbon Dioxide Percentage	(%CO <sub>2</sub> )	%	4.85	
Oxygen Percentage	(%O <sub>2</sub> )	%	17.2	
Carbon Monoxide Percentage	(%CO)	%	0.005	
Nitrogen Percentage	(%N <sub>2</sub> )	%	77.9	
Dry Gas Molecular Weight	(Md)	kg/Nm <sup>3</sup>	1.32	
Dry Gas Molecular Weight	(Md)	g/g-mole	29.5	
Wet Stack Gas Molecular Weight	(Ms)	g/g-mole	28.9	
Volumetric Flow Rate Data (at Sample Plane)				
Average Stack Gas Velocity	(vs)	m/sec	5.80	
Stack Diameter	Ds	m	1.20	
Stack Cross-Sectional Area	(As)	m <sup>2</sup>	1.13	
Upstream distance (from disturbance)	B	m	6.00	
Downstream distance (from disturbance)	A	m	8.00	
Actual Stack Flow Rate	(Qaw)	m <sup>3</sup> /min	394	
Wet Standard Stack Flow Rate	(Qsw)	Nm <sup>3</sup> /min-wet	257	
Dry Standard Stack Flow Rate	(Qsd)	Nm <sup>3</sup> /min-dry	244	
Percent of Isokinetic Rate	(I)	%	98.4	
Particulate Matter (PM) Concentration				
Total Mass of Particulates	(mn)	g	0.002	
Stack PM Concentration	(cs)	mg/Nm <sup>3</sup>	2.23	
Stack PM Concentration at 14 % O <sub>2</sub>	(cs)	mg/Nm <sup>3</sup>	4.19	
Particulate Emission Rate	(E)	g/min	0.544	
Instrumental Analyser Raw Data Averages				
Oxides of Nitrogen	(NO <sub>x</sub> )	ppm	29.2	
Carbon Monoxide	(CO)	ppm	48.0	
Average Oxides of Nitrogen (USEPA Method 7E - instrumental analyser)				
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	(Conc)	mg/Nm <sup>3</sup>	59.9	
Nitrogen Oxides at 14 % O <sub>2</sub>	(Conc)	mg/Nm <sup>3</sup>	113	
Nitrogen Oxides (NO <sub>x</sub> as NO <sub>2</sub> )	(E)	g/min	14.6	
Average Carbon Monoxide (USEPA Method 10 - instrumental analyser)				
Carbon Monoxide (CO)	(Conc)	mg/Nm <sup>3</sup>	60.0	
Carbon Monoxide at 14 % O <sub>2</sub>	(Conc)	mg/Nm <sup>3</sup>	113	
Carbon Monoxide (CO)	(E)	g/min	14.7	