

FINAL REPORT

CERTIFICATE No.: 23412



Boral Cement Limited
ABN 62 008 528 523
Taylor Avenue New Berrima NSW 2577
Locked Bag 4 New Berrima NSW 2577
T +61 2 4860 2222
F +61 2 4860 2257

TEST CERTIFICATE OF: Geelong Daily Despatch General Purpose Bulk Cement
PRODUCED AT: Boral Cement Limited Geelong
TESTED AT: Berrima Works Laboratory
SAMPLE IDENTIFICATION: GDDGP2200686
DATE DESPATCHED: 15/03/2022

PROPERTY	REQUIREMENTS OF AS 3972		RESULT
SO ₃ (AS 2350.2)	Maximum	3.5 %	2.8 %
Cl (AS 2350.2)	Maximum	0.10 %	0.02 %

OTHER REPORTABLE PROPERTIES

CHEMICAL		PHYSICAL	
K ₂ O (AS 2350.2)	0.36 %	Fineness Index (AS 2350.8)	410 m ² /kg
Na ₂ O (AS 2350.2)	0.21 %		
LOI (AS 2350.2)	2.8 %		

REMARKS

Sampling not carried out by laboratory. Samples tested as received.
This cement is a Type GP cement with up to 7.5% mineral addition.



Accredited for compliance with ISO/IEC 17025 - Testing

Marc Smith
Technical Services Manager
Date of Issue: 29/03/2022

**Boral Construction Materials
Materials Technical Services**

 Unit 4, 3-5 Gibbon Road
Baulkham Hills NSW 2153 Australia

PO Box 400, Winston Hills NSW 2153

T +61 (02) 9624 9900

boral.com.au
TEST REPORT
CLIENT: BORAL CEMENT – (TECHNICAL)

FILE NO: 50/22

ADDRESS: 39 Delhi Road, North Ryde, NSW 2113

REQUEST NO: 98668

TEST METHOD: AS/NZS 2350: Method of Testing Portland and Blended Cements

CEMENT IDENTIFICATION: GDDGP2200686

LAB. SAMPLE NO: 264969

SAMPLE SOURCE: Boral Cement - Geelong

DATE SAMPLED: 15/03/2022

DATE RECEIVED: 21/03/2022

Results
Date of cast: 29/03/2022

PROPERTY	DATE TESTED	TEST METHOD	RESULT
Compressive strength - 3 days	01/04/2022	AS/NZS 2350.11	32.5 MPa
Compressive strength - 7 days	05/04/2022	AS/NZS 2350.11	45.8 MPa
Compressive strength - 28 days	26/04/2022	AS/NZS 2350.11	59.2 MPa
Normal Consistency	02/05/2022	AS/NZS 2350.3	28.0%
Setting Time	Initial Set	AS/NZS 2350.4	120 Minutes
	Final Set	AS/NZS 2350.4	195 Minutes
Soundness	03/05/2022	AS/NZS 2350.5	1 mm

Note:

- Cement was provided by the client and tested as received.

Marc Smith, Parisa Sowti, Violeta Paicu, Mat. File, File

 Approved Signatory Julius C. Alvaro Julius Alvaro
 Date 07/05/2022 Serial No. CEM98668.JA.9
