

# FINAL REPORT

CERTIFICATE No.: 22910



Boral Cement Limited  
ABN 62 008 528 523  
Taylor Avenue New Berrima NSW 2577  
Locked Bag 4 New Berrima NSW 2577  
T +61 2 4860 2222  
F +61 2 4860 2257

**TEST CERTIFICATE OF:** Berrima Weekly Despatch Imported White Cement  
**PRODUCED AT:** Imported Product  
**TESTED AT:** Berrima Works Laboratory  
**SAMPLE IDENTIFICATION:** JKDWC2103021  
**DATE DESPATCHED:** 23/09/2021

PROPERTY	REQUIREMENTS OF AS 3972		RESULT
SO <sub>3</sub> (AS 2350.2)	Maximum	3.5 %	3.2 %
Cl (AS 2350.2)	Maximum	0.10 %	0.06 %

## OTHER REPORTABLE PROPERTIES

### CHEMICAL

K<sub>2</sub>O (AS 2350.2) 0.33 %  
Na<sub>2</sub>O (AS 2350.2) 0.20 %  
LOI (AS 2350.2) 2.9 %

### PHYSICAL

Fineness Index (AS 2350.8) 345 m<sup>2</sup>/kg  
Brightness \* (TM 10.01.12) 88.4 %

## REMARKS

Sampling not carried out by laboratory. Samples tested as received.

\* NATA accreditation does not cover the performance of this service.



Accredited for compliance with ISO/IEC 17025 - Testing

NATA Accreditation Number: 530 / 531

Page 1 of 1

Marc Smith  
Technical Services Manager  
Date of Issue: 29/03/2022

**TEST REPORT****CLIENT:** BORAL CEMENT – (TECHNICAL)**FILE NO:** 50/22**ADDRESS:** 39 Delhi Road, North Ryde, NSW 2113**REQUEST NO:** 98200**TEST METHOD:** AS/NZS 2350: Method of Testing Portland and Blended Cements**CEMENT IDENTIFICATION:** JKDWC2103021**LAB. SAMPLE NO:** 263747**SAMPLE SOURCE:** Maldon**DATE SAMPLED:** 23/09/2021**DATE RECEIVED:** 21/02/2022**Results**Date of cast: 25/02/2022

PROPERTY	DATE TESTED	TEST METHOD	RESULT
Compressive strength - 3 days	28/02/2022	AS/NZS 2350.11	43.6 MPa
Compressive strength - 7 days	04/03/2022	AS/NZS 2350.11	51.8 MPa
Compressive strength - 28 days	25/03/2022	AS/NZS 2350.11	62.8 MPa
Normal Consistency	28/02/2022	AS/NZS 2350.3	28.0%
Setting Time Initial Set	28/02/2022	AS/NZS 2350.4	105 Minutes
Final Set	28/02/2022	AS/NZS 2350.4	165 Minutes
Soundness	01/03/2022	AS/NZS 2350.5	1 mm

**Note:**

- Cement was provided by the client and tested as received.

Marc Smith, Parisa Sowti, Violeta Paicu, Mat. File, File

Approved Signatory Julius C. Alvaro Julius Alvaro  
Date 25/03/2022 Serial No. CEM98200.JA.6

