

FINAL REPORT

CERTIFICATE No.: 23558



Boral Cement Limited
ABN 62 008 528 523
Taylor Avenue New Berrima NSW 2577
Locked Bag 4 New Berrima NSW 2577
T +61 2 4860 2222
F +61 2 4860 2257

TEST CERTIFICATE OF: Maldon Daily Despatch General Purpose Bagged Cement
PRODUCED AT: Boral Cement Limited Maldon
TESTED AT: Berrima Works Laboratory
SAMPLE IDENTIFICATION: MBGGP2201107
DATE DESPATCHED: 19/04/2022

PROPERTY	REQUIREMENTS OF AS 3972		RESULT
SO ₃ (AS 2350.2)	Maximum	3.5 %	2.7 %
Cl (AS 2350.2)	Maximum	0.10 %	0.01 %

OTHER REPORTABLE PROPERTIES

CHEMICAL

K₂O (AS 2350.2) 0.57 %
Na₂O (AS 2350.2) 0.07 %
LOI (AS 2350.2) 1.4 %

PHYSICAL

Fineness Index (AS 2350.8) 360 m²/kg

REMARKS

Sampling not carried out by laboratory. Samples tested as received.
This cement is a Type GP cement with up to 7.5% mineral addition.



Accredited for compliance with ISO/IEC 17025 - Testing

Marc Smith
Technical Services Manager
Date of Issue: 19/05/2022

**Boral Construction Materials
Materials Technical Services**Unit 4, 3-5 Gibbon Road
Baulkham Hills NSW 2153 Australia

PO Box 400, Winston Hills NSW 2153

T +61 (02) 9624 9900

boral.com.au**TEST REPORT****CLIENT:** BORAL CEMENT – (TECHNICAL)**FILE NO:** 50/22**ADDRESS:** 39 Delhi Road, North Ryde, NSW 2113**REQUEST NO:** 99256**TEST METHOD:** AS/NZS 2350: Method of Testing Portland and Blended Cements**CEMENT IDENTIFICATION:** MBGGP2201107**LAB. SAMPLE NO:** 266644**SAMPLE SOURCE:** Maldon**DATE SAMPLED:** 19/04/2022**DATE RECEIVED:** 26/04/2022**Results**Date of cast: 13/05/2022

PROPERTY	DATE TESTED	TEST METHOD	RESULT
Compressive strength - 3 days	16/05/2022	AS/NZS 2350.11	29.3 MPa
Compressive strength - 7 days	20/05/2022	AS/NZS 2350.11	40.4 MPa
Compressive strength - 28 days	10/06/2022	AS/NZS 2350.11	60.9 MPa
Normal Consistency	14/06/2022	AS/NZS 2350.3	28.2%
Setting Time Initial Set	14/06/2022	AS/NZS 2350.4	120 Minutes
Final Set	14/06/2022	AS/NZS 2350.4	225 Minutes
Soundness	15/06/2022	AS/NZS 2350.5	1 mm

Note:

- Cement was provided by the client and tested as received.

Marc Smith, Parisa Sowti, Violeta Paicu, Mat. File, File

Approved Signatory



Julius Alvaro

Date

22/06/2022

Serial No.

CEM99256.JA.8

Accredited for compliance with ISO/IEC 17025 – Testing

This report shall not be reproduced in full without the approval of the Boral MTS Laboratory.

Test results in this Test Report relate only to the samples tested.

**NATA Accredited Laboratory****Number: 547**