


**Boral Construction Materials
Materials Technical Services**

 Unit 4, 3-5 Gibbon Road
 Baulkham Hills NSW 2153 Australia
 PO Box 400, Winston Hills NSW 2153

T: +61 (02) 9624 9900

F: +61 (02) 9624 9999

www.boral.com.au

TEST REPORT – MILLED SLAG
CLIENT: BORAL CEMENT – MALDON CEMENT
 Address: MALDON BRIDGE ROAD, MALDON, NSW 2571
FILE NO: 50/21**REQUEST NO:** 92859**LAB SAMPLE NO:** 248671**SOURCE OF SAMPLE:** Maldon**DATE RECEIVED:** 14/01/2021**SAMPLE IDENTIFICATION:** Enviroment ID # MDDNM2100079 - w/e 16/01/2021 - Date sampled: 11/01/2021**IDENTIFICATION OF CEMENT USED:** Boral Cement SL Berrima Ref. 2019**TEST METHOD: AS3583:** Methods of test for supplementary cementitious materials for use with Portland Cement

PROPERTY	TEST METHOD	RESULT	DATE TESTED
Fineness by the 45µm sieve	AS 3583.1	99%	28/01/2021
Relative density	AS 3583.5	2.91	20/01/2021
Relative water requirement	AS 3583.6	100%	21/01/2021
Relative strength 7 days (accelerated)	AS 3583.6	111%	28/01/2021
Relative strength 28 days (standard)	AS 3583.6	95%	18/02/2021

Violeta Paicu, Brad Vanderburg, Parisa Sowti, Mat File, File

Note:

- Sample was provided by the client and tested as received.



Approved Signatory

Sharjeel Mahmood

Date 19-02-2021

Serial No.

CEM92859.SM.1
 Accredited for compliance with ISO/IEC 17025 - Testing
 This report shall not be reproduced except in full without the approval of the Boral MTS Laboratory
 Test results in this Test Report relate only to the samples tested

NATA Accredited Laboratory

Number: 547



**Boral Construction Materials
Materials Technical Services**

Unit 4, 3-5 Gibbon Road
Baulkham Hills NSW 2153 Australia
PO Box 400, Winston Hills NSW 2153

T: +61 (02) 9624 9900

F: +61 (02) 9624 9999

www.boral.com.au

TEST REPORT

CLIENT: BORAL CEMENT – Maldon Cement
Maldon Bridge Road, Maldon, NSW 2571.

FILE No.:50/21

PROJECT: Testing of Maldon Enviroment Weekly Sample.

REQUEST No.: 92859

TEST PROCEDURE:

AS 3583.12 – 1991 – Determination of Available Alkali

Laboratory Sample No.: 248671
Date Sampled: 11/01/21
Date Received: 14/01/21
Date Tested: 17/02/21
Sample Description: Enviroment ID #
MDDNM2100079
Field No.: 1

TEST RESULTS:

Sodium as Na₂O (%) 0.03
Potassium as K₂O (%) 0.04
Available Alkali (%) 0.1


Available Alkali (%) = Na₂O (%) + (0.658 x K₂O %)

Note:

- Sample was provided by the Client and tested as received.

V.Paicu, B.Vanderburg,P.Sowti, Mat.File, File.



Approved Signatory  Nanthini Selvadurai
Date 18-02-21 Serial No. CHEM92859.NS.1

Accredited for compliance with ISO/IEC 17025 - Testing
This report shall not be reproduced except in full without the approval of the Boral MTS Laboratory
Test results in this Test Report relate only to the samples tested

NATA Accredited Laboratory

Number: 9968