

# FINAL REPORT

CERTIFICATE No.: 22424



Boral Cement Limited  
ABN 62 008 528 523  
Taylor Avenue New Berrima NSW 2577  
Locked Bag 4 New Berrima NSW 2577  
T +61 2 4860 2222  
F +61 2 4860 2257

**TEST CERTIFICATE OF:** Somerton Daily Despatch Pozzoment  
**PRODUCED AT:** Boral Cement Limited Somerton  
**TESTED AT:** Berrima Works Laboratory  
**SAMPLE IDENTIFICATION:** SDDPZ2101251  
**DATE DESPATCHED:** 26/04/2021

| PROPERTY                          | REQUIREMENTS OF AS 3972 |          | RESULT   |
|-----------------------------------|-------------------------|----------|----------|
| Compressive Strength (AS 2350.11) |                         |          |          |
| 3 Day                             |                         |          | 24.2 MPa |
| 7 Day                             | Minimum                 | 20 MPa   | 33.5 MPa |
| 28 Day                            | Minimum                 | 35 MPa   | 50.7 MPa |
| Setting Time (AS 2350.4)          |                         |          |          |
| Initial                           | Minimum                 | 45 mins  | 150 mins |
| Final                             | Maximum                 | 600 mins | 210 mins |
| Soundness (AS 2350.5)             | Maximum                 | 5 mm     | 0 mm     |
| SO <sub>3</sub> (AS 2350.2)       | Maximum                 | 3.5 %    | 1.8 %    |
| CI (AS 2350.2)                    | Maximum                 | 0.10 %   | 0.02 %   |

## OTHER REPORTABLE PROPERTIES

### CHEMICAL

### PHYSICAL

|                                |                        |
|--------------------------------|------------------------|
| Normal Consistency (AS 2350.3) | 28.3 %                 |
| Fineness Index (AS 2350.8)     | 380 m <sup>2</sup> /kg |

## REMARKS

Preparation of mortar and moulding of specimens in accordance with AS 2350.12.  
Sampling not carried out by laboratory. Samples tested as received.  
This blended cement is a Type GB cement with nominally 75% cement / 25% fly ash.



Accredited for compliance with ISO/IEC 17025 - Testing

NATA Accreditation Number: 530 / 531

Page 1 of 1

Marc Smith  
Technical Services Manager  
Date of Issue: 9/07/2021