

# FINAL REPORT

CERTIFICATE No.: 23076



Boral Cement Limited  
ABN 62 008 528 523  
Taylor Avenue New Berrima NSW 2577  
Locked Bag 4 New Berrima NSW 2577  
T +61 2 4860 2222  
F +61 2 4860 2257

**TEST CERTIFICATE OF:** Waurn Ponds Daily Despatch General Purpose Bulk Cement  
**PRODUCED AT:** Boral Cement Limited Waurn Ponds  
**TESTED AT:** Berrima Works Laboratory  
**SAMPLE IDENTIFICATION:** WDDGP2103496  
**DATE DESPATCHED:** 15/11/2021

| PROPERTY                          | REQUIREMENTS OF AS 3972 |          | RESULT   |
|-----------------------------------|-------------------------|----------|----------|
| Compressive Strength (AS 2350.11) |                         |          |          |
| 3 Day                             |                         |          | 35.7 MPa |
| 7 Day                             | Minimum                 | 35 MPa   | 48.0 MPa |
| 28 Day                            | Minimum                 | 45 MPa   | 59.7 MPa |
| Setting Time (AS 2350.4)          |                         |          |          |
| Initial                           | Minimum                 | 45 mins  | 165 mins |
| Final                             | Maximum                 | 360 mins | 210 mins |
| Soundness (AS 2350.5)             | Maximum                 | 5 mm     | 1 mm     |
| SO <sub>3</sub> (AS 2350.2)       | Maximum                 | 3.5 %    | 2.7 %    |
| Cl (AS 2350.2)                    | Maximum                 | 0.10 %   | 0.03 %   |

## OTHER REPORTABLE PROPERTIES

### CHEMICAL

K<sub>2</sub>O (AS 2350.2) 0.42 %  
Na<sub>2</sub>O (AS 2350.2) 0.25 %  
LOI (AS 2350.2) 2.8 %

### PHYSICAL

Normal Consistency (AS 2350.3) 27.3 %  
Fineness Index (AS 2350.8) 380 m<sup>2</sup>/kg

## REMARKS

Preparation of mortar and moulding of specimens in accordance with AS 2350.12.  
Sampling not carried out by laboratory. Samples tested as received.  
This cement is a Type GP cement with up to 7.5% mineral addition.



Accredited for compliance with ISO/IEC 17025 - Testing

NATA Accreditation Number: 530 / 531

Page 1 of 1

Marc Smith  
Technical Services Manager  
Date of Issue: 2/02/2022