

## FINAL REPORT

CERTIFICATE No.: 24477



Boral Cement Limited  
N 62 008 528 523  
Taylor Avenue New Berrima NSW 2577  
Locked Bag 4 New Berrima NSW 2577  
T +61 2 4860 2222

**TEST CERTIFICATE OF:** Tarong Daily Despatch Grade 1 Fly Ash  
**PRODUCED AT:** Boral Cement Limited Tarong  
**TESTED AT:** Berrima Works Laboratory  
**SAMPLE IDENTIFICATION:** TDDFA2204707  
**DATE DESPATCHED:** 15/12/2022

PROPERTY	REQUIREMENTS OF AS 3582.1 - Grade 1	RESULT
Fineness (AS 3583.3)	≥ 75 %	85 %
LOI (AS 3583.3)	≤ 4.0 %	2.0 %
Moisture (AS 3583.2)	≤ 0.5 %	0.2 %
SO <sub>3</sub> (AS 2350.2)	≤ 3.0 %	0.1 %
SiO <sub>2</sub> (AS 2350.2)		69.7 %
Al <sub>2</sub> O <sub>3</sub> (AS 2350.2)		23.3 %
Fe <sub>2</sub> O <sub>3</sub> (AS 2350.2)		3.0 %
Chemical Composition (AS 2350.2)	≥ 70 %	96 %
Total Alkali (AS 2350.2)		0.4 %
Cl (AS 2350.2)	≤ 0.1 %	< 0.01 %

### REMARKS

Sampling not carried out by laboratory. Samples tested as received.



Accredited for compliance with ISO/IEC 17025 - Testing

Marc Smith  
Technical Services Manager

**Boral Construction Materials  
Materials Technical Services**Unit 4, 3-5 Gibbon Road  
Baulkham Hills NSW 2153 Australia

PO Box 400, Winston Hills NSW 2153

T +61 (02) 9624 9900

**boral.com.au****TEST REPORT – FLYASH****CLIENT:** BORAL CEMENT – (TECHNICAL)**FILE NO:** 50/23**ADDRESS:** 39 Delhi Road, North Ryde, NSW 2113**REQUEST NO:** 103831**SAMPLE IDENTIFICATION:** TDDFA2204707 – Silo B**LAB SAMPLE NO:** 278571**SOURCE OF SAMPLE:** Boral Cement - Berrima**DATE SAMPLED:** 15/12/2022**DATE RECEIVED:** 25/01/2023**IDENTIFICATION OF CEMENT USED:** Boral Cement SL Berrima Ref. 2019**TEST METHOD:** AS 3583: Methods of test for supplementary cementitious materials for use with Portland cement

PROPERTY	DATE TESTED	RESULT	TEST METHOD
Relative density	08/02/2023	2.13	AS 3583.5
Relative water requirement	14/02/2023	101%	AS 3583.6
Relative strength 7 days (accelerated)	21/02/2023	94%	AS 3583.6

**Note:**

- Sample supplied by the client and tested as received.

Marc Smith, Parisa Sowti, Violeta Paicu, Stephanie Koehler, Mat. File, File

Approved Signatory



Julius Alvaro

Date

24/02/2023

Serial No.

CEM103831.JA.1

Accredited for compliance with ISO/IEC 17025 – Testing

This report shall not be reproduced in full without the approval of the Boral MTS Laboratory.

Test results in this Test Report relate only to the samples tested.

**NATA Accredited Laboratory****Number: 547**