

FINAL REPORT

CERTIFICATE No.: 27927



Boral Cement Limited

ABN 62 008 528 523

Taylor Avenue New Berrima NSW 2577

Locked Bag 4 New Berrima NSW 2577

T +61 2 4860 2222

TEST CERTIFICATE OF: Tarong Daily Despatch Grade 1 Fly Ash
PRODUCED AT: Boral Cement Limited Tarong
TESTED AT: Boral Cement QA Laboratory
SAMPLE IDENTIFICATION: TDDFA2600311
DATE DESPATCHED: 28/01/2026

| PROPERTY | REQUIREMENTS OF AS 3582.1 - Grade 1 | RESULT |
|--|-------------------------------------|----------|
| Fineness (AS 3583.1) | ≥ 75 % | 84 % |
| LOI (AS 3583.3) | ≤ 4.0 % | 2.8 % |
| Moisture (AS 3583.2) | ≤ 0.5 % | 0.3 % |
| SiO ₂ (AS 2350.2) | | 68.4 % |
| Al ₂ O ₃ (AS 2350.2) | | 25.1 % |
| Fe ₂ O ₃ (AS 2350.2) | | 1.3 % |
| Chemical Composition (AS 2350.2) | ≥ 70 % | 95 % |
| Total Alkali (AS 2350.2) | | 0.4 % |
| Cl (AS 2350.2) | ≤ 0.1 % | < 0.01 % |

REMARKS

Sampling not carried out by laboratory. Samples tested as received and results only relate to the item tested.



Accredited for compliance with ISO/IEC 17025 - Testing

A handwritten signature in blue ink, appearing to read "Melody Mancenido".

Melody Mancenido
Technical Services Manager



Building something great

TEST REPORT – FLYASH

CLIENT: BORAL CEMENT – (TECHNICAL)

FILE NO: 50/26

ADDRESS: 39 Delhi Road, North Ryde, NSW 2113

REQUEST NO: 122598

SAMPLE IDENTIFICATION: TDDFA2600311

LAB SAMPLE NO: 333594

SOURCE OF SAMPLE: Queensland

DATE SAMPLED: 28/01/2026

DATE RECEIVED: 30/01/2026

IDENTIFICATION OF CEMENT USED: Boral Cement SL Berrima Ref. 2022

TEST METHOD: AS 3583: Methods of test for supplementary cementitious materials for use with Portland cement

| PROPERTY | DATE TESTED | RESULT | TEST METHOD |
|--|-------------|--------|-------------|
| Relative density | 25/02/2026 | 2.10 | AS 3583.5 |
| Relative water requirement | 26/02/2026 | 101% | AS 3583.6 |
| Relative strength 7 days (accelerated) | 05/03/2026 | 100% | AS 3583.6 |
| Relative strength 28 days (standard) | 26/03/2026 | 98% | AS 3583.6 |

Note:

- Sample supplied by the client and tested as received.

Approved signatory _____

Sam El-Hamawi

Date 07/04/2026

Serial no. CEM122598.SE.1

