

# VOC Content Test Certificate

Tuesday October 20<sup>th</sup>, 2009

Supplier: Blue Circle Southern Cement (Clunies Ross Street, Prospect NSW 2148)

Sample Description: General Purpose Cement

Date Tested: October 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

**General Purpose Cement**

**10 grams per Litre as VOC content of material**



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0909-42**